

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Our water system recently violated drinking water standards. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

Longtown RW&Sd #1 (Pittsburg Co.) Has Levels of Total Trihalomethanes (TTHMs) Above Drinking Water Standard

We routinely monitor for the presence of drinking water contaminants. Testing results we received for the indicated time period(s) show that our system exceeds the standard, or maximum contaminant level (MCL), for total trihalomethanes (TTHM). The standard or MCL for TTHM is 0.080 mg/L. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of total trihalomethanes averaged at our system's locations was the following:

<u>Twelve-month time period</u>	<u>Locational Running Annual Average with Sample Location</u>
Fourth Quarter 2025	0.097 MG/L - 264 HUNTER RD EUFAULA, OK
Fourth Quarter 2025	0.085 MG/L - MURPHY DRIVE ROCK CREEK COVE TOWER
Third Quarter 2025	0.093 MG/L -264 HUNTER RD EUFAULA, OK
Third Quarter 2025	0.083 MG/L -MURPHY DRIVE ROCK CREEK COVE TOWER
Second Quarter 2025	0.091 MG/L -MURPHY DRIVE ROCK CREEK COVE TOWER
First Quarter 2025	0.088 MG/L -264 HUNTER RD EUFAULA, OK
First Quarter 2025	0.117 MG/L -MURPHY DRIVE ROCK CREEK COVE TOWER

What should I do? There is nothing you need to do unless you have a severely compromised immune system, have an infant or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately.

However, some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

Longtown RW&Sd #1 (Pittsburg Co.) Has Levels of Haloacetic Acids (HAA5) Above Drinking Water Standards

We routinely monitor for the presence of drinking water contaminants. Testing results we received for the indicated time period(s) show that our system exceeds the standard, or maximum contaminant level (MCL), for haloacetic acids (HAA5). The standard or MCL for HAA5 is 0.060 mg/L. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of haloacetic acids averaged at our system's locations was the following:

<u>Twelve-month time period</u>	<u>Locational Running Annual Average with Sample Location</u>
Fourth Quarter 2025	0.062 MG/L - 264 HUNTER RD EUFAULA, OK

What should I do? There is nothing you need to do unless you have a severely compromised immune system, have an infant or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately. However, some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer

CORRECTIVE ACTION: What happened? What is being done? When will the violation be resolved?

HACH COMPANY JUST INSTALLED NEW TURBIDITY METERS, SENSORS AND FILTERS. CHECK THE BREAKER AND THE MECHANICAL FUNCTION OF THE MIXER/BLOWER AT ROCK CREEK. NEW MIXERS ARE GETTING INSTALLED FRIDAY AT STANDING ROCK AND CASTANAWAY #2. IMPLEMENT MORE FLUSHING REGIMENT. WATERTECH IS SCHEDULED TO DO A JAR TEST AT THE PLANT AND FIELD SITE LOCATIONS.

For further information contact: LONGTOWN RW&S DISTRICT #1, 918-452-3685

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Longtown RW&Sd #1 (Pittsburg Co.)

PWS Number OK1020623

Date distributed: 3/23/2028